

INSTITUTO DE CIENCIAS DE LA CONSTRUCCIÓN EDUARDO TORROJA

C/ Serrano Galvache, 4. 28033 Madrid (Spain) Tel.: (+34) 91 302 0440 www.ietcc.csic.es gestiondit@ietcc.csic.es dit.ietcc.csic.es





European Technical Assessment ETA 24/0336 of 19/04/2024

English translation prepared by IETcc. Original version in Spanish language

General Part

Technical Assessment Body issuing the European Technical Assessment:

Instituto de Ciencias de la Construcción Eduardo Torroja (IETcc)

Trade name of the construction

product

Torggler Flex PU System

Product family to which

construction product belongs

Liquid Applied Roof Waterproofing Kit, based on polyurethane

Manufacturer Via Prati Nuovi, 9

39020 Marlengo (BZ) Italy

Manufacturing plant(s)

Plant 1

This European Technical **Assessment contains**

6 pages

+ Annex 1 contains confidential information and is not included in the European Technical Assessment when that

assessment is publicly disseminated

This European Technical Assessment is issued in accordance with Regulation (EU) No 305/2011, on the basis of

EAD 030350-00-0402

Liquid applied roof waterproofing kits

Translations of this European Technical Assessment in other languages shall fully correspond to the original issued document and should be identified as such.

Communication of this European Technical Assessment, including transmission by electronic means, shall be in full (excepted the confidential Annex(es) referred to above). However, partial reproduction may be made, with the written consent of the issuing Technical Assessment Body. Any partial reproduction has to be identified as such.



Specific parts

1 Technical description of the product

The Liquid Applied Roof Waterproofing Kit (LARWK) "Torggler Flex PU System" is designed and installed in accordance with the manufacturer design and installation instructions. This LARWK comprises the following components and systems, which are produced by the manufacturer.

	Components	Trade name	Consume	
Primer over concrete metal and PU		TORGGLER Flex PU Primer 2K: epoxy water based	≥ 0.15 kg/m ²	
		TORGGLER FLEX PU	≥ 2.3 kg/m ²	
System 1	Waterproofing membrane	+ 3 % (weight) TORGGLER CATALISER (+ Optional: TORGGLER FLEX PU WALK)		
	Internal mesh	TORGGLER Geotex		
System 2	Waterproofing membrane	TORGGLER FLEX PU + 3 % (weight) TORGGLER CATALISER	≥ 1.8 kg/m ²	
	Finish layer: UV Protection	TORGGLER FLEX PU WALK	≥ 0.15 kg/m ²	

TORGGLER FLEX PU is a mono component liquid applied roof waterproofing based on polyurethane consisting of a polyurethane elastomeric membrane without or with internal mesh; which once polymerized conforms an elastic lining, in form of a layer completely bonded to the support (steel, concrete, mortar, ceramic, PU, PU) and other waterproofing membranes like PVC, EPDM and bituminous (for each kind of substrate application with suitable primer, following the indications of the manufacturer). TORGGLER CATALISER is added to TORGGLER FLEX PU (3 % weight) during application of thick layers as an accelerator for faster curing.

TORGGLER FLEX PU WALK is a mono component liquid applied roof waterproofing based on an aliphatic polyurethane, that is applied on TORGGLER FLEX PU (once it is dry, following the manufacturer instructions).

The minimum layer thickness of the assembled system has to be 1.0 mm without internal mesh and 1.2 mm with internal mesh.

2 Specification of the intended use in accordance with the applicable European Assessment Document (hereinafter EAD)

2.1 Intended use(s)

The intended use of this System is the waterproofing of roof against the water, as in liquid as vapour form, with any slope between 0 and >30 % (S1-S4), for any type of categorisation of user load between P1 a P3 and resists the effects of low surface temperatures of –30 °C (TL4) and high temperatures from 90 °C (TH4) to 30 °C (TH1)¹. This LARWK fulfils the Basic works requirements n.º 2 (Safety in case of fire), n.º 3 (Hygiene, health and the environment) and n.º 4 (Safety in use) of the European Regulation 305/11.

This LARWK is made of non load-bearing construction elements. It does not contribute directly to the stability of the roof on which is installed, but it can contribute its durability by providing enhanced protection from the effect of weathering.

This LARWK can be used on new or existing (retrofit) roofs. It can also be used on vertical surfaces (singular details).

2.2 Relevant general conditions for the use of the kit

The provisions made in this European Technical Assessment are based on an assumed working life of 25 years from installation in the works, according to EAD030350-00-0402, provided that the conditions lay down for the installation, packaging, transport and storage as well as appropriate use, maintenance and repair are met. In this respect.

The indications given on the working life cannot be interpreted as a guarantee given neither by the product manufacturer nor by EOTA nor by the Technical Assessment Body issuing this ETA, but are regarded only as a means for choosing the right product in relation to the expected economically reasonable working life of the works.

ETA 24/0336 - version 1 of 19/04/2024 - page 2 of 6



¹ Support; Concrete / steel: P3: TH2 - TH1 // P2: TH4 - TH3 Support; PU: without mesh P1: TH4 - TH1 // With mesh: P2: TH4 - TH1

Installation. The Kit is installed on site. It is the responsibility of the manufacturer to guarantee that the information about design and installation of this system is effectively communicated to the concerned people. This information can be given using reproductions of the respective parts of this ETA. Besides, all the data concerning the execution shall be clearly indicated on the packaging and/or the corresponding technical documents.

<u>Design.</u> The fitness for the respective use for the levels of performance of this System stated in Annex 1 complies with the EOTA requirements. In the MTD the manufacturer gives information on the quantities consumed and the processing, which shall lead to a thickness of the roof waterproofing \geq 1.0 mm without internal mesh and \geq 1.2 mm with internal mesh.

Execution. Particularly, it is recommended to consider the:

- kit installation that has to be carried out by qualified installers and only the components of the kit indicated in this ETA can be used,
- minimum thickness of the kits can be ensured by supervision of the amount of material used (kg/m²) and visual control to check that each coating covers totally the one below,
- inspection of the roof surface (cleanliness and correct preparation) before applying the roof waterproofing,
- recommended temperature of the product to be assembled will be between 5 °C and 35 °C, substrate temperatures will not be more than 40 °C and substrate humidity will not be more than 5%. In other conditions it will need to follow the manufacturer's instructions.

Before, the installation of Torggler Flex PU System, it is recommended to read the safety data sheets of the different components of the system.

Use, maintenance and repair of the works. Roofs with deteriorated areas of waterproofing layers will be repaired following the installation instructions of the manufacturer. Further installation details are laid down in the MTD placed at IETcc.

3 Performance of the product and references to the methods used for its assessment

The identification tests and the assessment for the intended use of "Torggler Flex PU System" according to the Basic Work Requirements (BWR) were carried out in compliance with EAD 030350-00-0402. The characteristics of each system shall correspond to the respective values laid down in following tables of this ETA, checked by IETcc.

Methods of verification and of assessing and judging are listed afterwards.

3.1 Safety in case of fire (BWR 2)

Basic requirement for construction works 2: Safety in case of fire				
Essential characteristic	Relevant clause in EAD	Performance		
External fire performance	2.2.1	System 1 without TORGGLER FLEX PU WALK: BROOF (t4) for pitches ≤ 10° and non-combustibles support. For other types of supports and pitches: NPA System 2 with TORGGLER FLEX PU WALK: NPA		
Reaction to fire	2.2.2	NPA		

3.2 Hygiene, health and environment (BWR 3)

Basic requirement for construction works 3: Hygiene, health, and the environment					
Essential characteristic	Relevant clause in EAD	Performance			
Content, emission and/or release of dangerous substances	2.2.3	NPA			
Resistance to water vapour	2.2.4	μ = 1620 (1.2 mm thickness)			
Watertightness	2.2.5	Watertight			
	o wind loads 2.2.6	Support + Primer + Membrane	> 50 kPa		
Resistance to wind loads		Concrete	3800		
Resistance to wind loads	2.2.0	Steel	2100		
		PU	200		

ETA 24/0336 - version 1 of 19/04/2024 - page 3 of 6



	2.2.7	Concrete / steel P3: TH2 - TH1 /TL4		Poliurethane foam (PU) Without mesh: P1: TH4 - TH1 / TL4	
		P2: TH4 - TH3 / TL4 With mesh: P2: TH4 - TH1 / TL4 Resistance to dynamic indentation (23 °C) without /with			
Resistance to mechanical damage (perforation)	2.2.7.1	Concrete		14 (6	mm)) mm)
	2.2.7.2	Resistance to static indentation (23 °C) without / with internal mesh			
		Pl		L4 (250 N) L3 (200 N)	
Resistance to fatigue movement	2.2.8	W3 1000 cycles (-10 °C). Pass			00 14)
	2.2.9	Low temperatures: TL4 High temperatures: TH4			
	2.2.9.1	R. Dynamic Indentation (without / with internal mesh)		Concrete / Steel	I4 (6 mm)
		at -30		PU	I2 (20 mm)
Resistance to the effects of low	2.2.9.2	Crack bridin	g capability		-30 °C)
and high surface temperatures	2.2.9.3	R. Static Indentation (without / with	Steel / Concrete	90 – 80 °C 60 °C 30 °C	L2 / L2 L3 /L3 L4/ L4
	2.2.9.3	internal mesh)	PU	90 – 80 – 60 °C	L1 / L2
		,		30 °C	L2 / L3
				geing W3, S (se thout / with inter	
		Dynamic Indentation (-30 °C)		Concrete / Steel	14 / 14
		Fotigue movem	ant (E0 avaloa)	PU	I1 / I2
	0.0404	Fatigue movement (50 cycles) at -10 °C		Pass	
	2.2.10.1			Without mesh	Initial: 4.5 / 367 Ageing: 2.5 / 135
Resistance to ageing media (heat and water)		Tensile properties (MPa / %)		With mesh	Initial: 8 / 27 Ageing:
					6 / 40
		Resistance to water ageing W3, After 60 days immersion water at 60 °C			
		Static Indentation, 60	Concrete /	90 -80 °C	L2 / L2
			steel	60 °C	L3 / L3
	2.2.10.3	days (without /		30 °C 90 -80 – 60	L4 / L4 L1 / L2
		mesh)	PU	°C 30 °C	L2 / L3
		Delamination s	trength: Pass	Concrete:	
		(<50 k		PU: 0.1	
		W3, S (severe), 5000 hours			
Resistance to UV radiation in the presence of moisture	0.0.40.0	Dynamic In (without / with in	dentation	Concrete / Steel	13 / 14
(5000 hours)	2.2.10.2	`	,	PU	12 / 13
		Tensile properti (without inter		Initial: 4 Ageing:	
Resistance to plant root	2.2.11		NF	PA	
	2.2.12	5 °C / 40 °C			
Effects of variations in kit		Dynamic Indentation without internal mesh at 23 °C Support steel/concrete: I4 (6 mm) Support PU: I3 (10 mm)			
components and site practices		Su		(i)
components and site practices		5 °C / 40 °C Tensile properties without internal mesh at 23 °C T. Strength (MPa): 5 / 5			
Effects of day joints	2.2.13	E	Elongation (%):	ε 438 / 361	
		J.T IVII a			

ETA 24/0336 - version 1 of 19/04/2024 - page 4 of 6



3.3 Safety and accessibility in use (BWR 4)

Basic requirement for construction works 4: Safety and accessibility in use					
Essential characteristic	Relevant clause in EAD	Performance			
Slipperiness	2.2.14	NPA			

4 Assessment and verification of constancy of performance (hereinafter AVCP) system applied, with reference to its legal base

4.1 System of assessment and verification of constancy of performance

According to the decision 98/599/EC of October 1998, Official Journal of the European Communities N° L 287, 24.10.1998) of the European Commission², system 3 of assessment and verification of constancy of performance (see EC delegated regulation (EU) No 568/2014 amending Annex V to Regulation (EU) N° 305/2011) applies.

Product	Intended uses	Level or Classes	System
Torggler Flex PU System	Liquid Applied Roof Waterproofing Kit	Any	3

5 Technical details necessary for the implementation of the AVCP system, as provided for in the applicable EAD

Technical details necessary for the implementation of the AVCP system are laid down in the control plan which is deposited at IETcc³.

5.1 Tasks of the manufacturer

Factory production control. The manufacturer shall exercise permanent internal control of production. All the elements, requirements and provisions adopted by the manufacturer shall be documented in a systematic manner in the form of written policies and procedures, including records of results performed. This production control system shall ensure that the product is in conformity with this ETA.

The manufacturer may only use components stated in the technical documentation of this ETA including Control Plan. The incoming raw materials are subjected to verifications by the manufacturer before acceptance.

The factory production control shall be in accordance with the Control Plan. The results of factory production control shall be recorded and evaluated in accordance with the provisions of the Control Plan

Other tasks of the manufacturer. The manufacturer shall make a declaration of conformity, stating that the construction product is in conformity with the provisions of this ETA.

5.2 Tasks of notified bodies

Initial type-testing of the product. For type testing, the results of the tests performed as part of the assessment for the European Technical Assessment shall be used unless there are changes in the production line or plant. In such cases, the necessary type testing has to be agreed between IETcc and the notified body.

The initial type-testing have been conducted by the IETcc to issue this ETA in accordance with the EAD 030350-00-0402 "Liquid applied roof waterproofing kits". The verifications underlying this ETA have been furnished on samples from the current production.

ETA 24/0336 - version 1 of 19/04/2024 - page 5 of 6



² Published in the Official Journal of the European Union (OJEU) L 262, 14/10/2003 P. 0034 - 0036.

See www.new.eur-lex.europa.eu/oj/direct-access.html

The Control Plan is a confidential part of the ETA and only handed over to the notified certification body involved in the assessment and verification of constancy of performance.

Issued in Madrid on 19 April 2024

Ву

Director on behalf of Instituto de Ciencias de la Construcción Eduardo Torroja (IETcc – CSIC)

ETA 24/0336 - version 1 of 19/04/2024 - page 6 of 6

